


## SANITARY SEWER CONNECTION DETAIL

NOT TO SCALE

**NOTES:**

1. PROPERTY OWNER IS RESPONSIBLE FOR THEIR SEWER CONNECTION TO THE SEWER MAIN.
2. SEWER PIPE & FITTINGS TO BE ASTM 3034, SDR 35. PIPING SHALL BE WATER TIGHT.
3. WHERE PROPERTY LINE IS LESS THAN 25 FEET FROM BUILDING, ONLY ONE CLEANOUT IS NEEDED.
4. ON SITE DISPOSAL SYSTEMS TO BE ABANDONED AND FILLED WITH SAND BY PROPERTY OWNERS.
5. NO FOUNDATION, YARD, ROOF DRAIN OR ANY OTHER CONNECTIONS PERMITTING ANYTHING OTHER THAN SANITARY SEWERAGE (AS DEFINED BY AUTHORITY RULES AND REGULATIONS) SHALL BE DISCHARGED TO THE SANITARY SEWER.



## CONNECTION TRENCH DETAIL

NOT TO SCALE

Scale		Date		Project Number		Drawn By		Checked By		Sheet Number	
N.T.S.		03/19/11		05-1300-0791		BAH		CMA		1 OF 1	
<p>Client: MUNICIPAL AUTHORITY OF THE BOROUGH OF EBENSBERG</p> <p>Title: SANITARY SEWER CONNECTION DETAIL</p>											