

**QUESTIONS/ANSWERS FOR**

**RESIDENTIAL SIDEWALK & CURB**

**SOUTH MARIAN STREET**  
**WEST TRIUMPH STREET**  
**SOUTH CAROLINE STREET**

- Q. Item No. 1 in section V of the GENERAL PROJECT NOTES indicates the use of ½” expansion every 30’ or less on the curb and sidewalk. Would you accept expansion joints in the curb at the end of each days pour if we elect to slip form the curb?
- A. The new curb can be slip formed. If so, saw cut the curb every 15 feet, within 24 hours of being poured.
- Q. The specifications call for “ornamental stone surfacing”. What is that?
- A. 2”-4” gradation river rock landscaping stone.
- Q. Who is responsible for obtaining any required permits?
- A. An HOP is required where Triumph Street meets Center Street (state road). The Borough has obtained that permit. An E&S Plan is required due to the scope of the project, and the Borough has obtained that permit. The contractor will have no responsibility for any permitting, except for employing required BMPs.
- Q. Should we include the cost for E&S in with the curb or sidewalk?
- A. Any costs incurred for E&S BMPs should be included in the curb costs.